

LUECO Bids and Awards Committee (BAC)

Quezon Avenue, San Fernando City

BID BULLETIN No. 7

CLARIFICATION

Please be informed that the **LUECO Bids and Awards Committee (BAC)** is issuing **Bid Bulletin No. 7** to provide clarifications on the required Annexes to be submitted as part of the Bid Submission.

To wit:

- 1) The Annexes that require Bidders to use their respective company letterheads, please be advised that the LUECO watermark should be removed.
- 2) Annex 7 – Contract Capacity and Reserve Capacity
 - **Contract Capacity** refers to the maximum amount of electrical power or energy that a utility or generator agrees to supply to a customer or grid under a contractual agreement (Power Supply Agreement or PSA).
 - **Net Dependable Capacity** refers to the maximum power output that a generating unit or power plant can consistently deliver under specified conditions, taking into account factors such as seasonal limitations and the power needed for its own operation (station service). This represents the reliable or current capacity available for use.
 - **Reserve Capacity** refers to the difference of the Net Dependable Capacity less the Contracted Capacity which is calculated as:

Reserve Capacity = Net Dependable Capacity – Contract Capacity

Please be guided accordingly.

For BAC:

The Secretariat